



POLICY FOR INSTALLATIONS OF WATER RESTRICTORS

Overview:

Whereas the community of Whitemouth has its own reservoir and separate pumping capacity, the community of Seven Sisters and the R.M. of Whitemouth rural water pipeline customers are fed directly from the distribution system. To prevent excess demand on the distribution system this policy provides for flow restrictors to be placed on all customers connected to the rural water pipeline distribution system, and any new customers connecting to the Seven Sisters/Townsite water system that are large users.

Definitions:

1. Seven Sisters/Townsite System: Shall include all customers serviced by the 200 mm main branching off the main distributions system and passing west through SE 27-13-11E
2. Whitemouth System: Shall include all customers serviced by the system originating at the pumphouse on Hospital St within in the community of Whitemouth.
3. R.M. of Whitemouth Rural Water Pipeline: Shall include all other customers connected to the water distribution system.
4. Elma System: Shall include all customer south of Township Road.

Policy:

1. All connections to the rural water pipeline shall have a flow restrictor in place.
2. All new connections to the Seven Sisters/Townsite system shall have a flow restrictor installed when the meter is installed if they are deemed by P.W. Committee to be a large user.
3. The customer shall be given a 3 GPM restrictor, unless the P.W. committee authorizes a 5 GPM restrictor based on use of the property.
4. The restrictor size shall not be dependent on meter size.